| | Energy Consumption and Gree | Energy Consumption and Greenhouse Gas Reporting | | | | | | | |
|-------------------|-------------------------------|--|--|--|--|--|--|--|--|
| 2016 | January 2016 - December 2016 | | | | | | | | |
| Sector | Acute/Chronic Hospital | | | | | | | | |
| Agency Sub-sector | Public Hospital | | | | | | | | |
| Organization Name | London Health Sciences Centre | | | | | | | | |

| Operation Name | Operation Type | Address | Total Floor Area | Unit | Avg hrs/wk | Electricity Quantity | Unit | Natural Gas Quantity | Unit | Fuel Oil 1 & 2 Quantity | Fuel Oil 1 & 2 Unit | District Heating Quantity | District Heating Unit | GHG Emissions (Kg) | Energy Intensity (ekWh/sq ft) |
|--------------------------------|---------------------------------------|--------------------------|---------------------|-----------------|---------------|-------------------------|------|-------------------------|----------------|-------------------------------|---------------------------|---------------------------------|--------------------------|-----------------------|--|
| Byron Family Medical Centre | Facilities used for hospital purposes | 1228 Commissioners Rd. | 12,147 | ft ² | 168 | 120,488 | kWh | 7,249 | m ³ | | | | | 17,988 | 16 |
| Kidney Care Centre | Facilities used for hospital purposes | 785 Wonderland Rd. S. | 29,202 | ft ² | 168 | 647,385 | kWh | 52,442 | m ³ | | | | | 122,162 | 2 41 |
| University Hospital | Facilities used for hospital purposes | 339 Windermere Rd. | 1,041,593 | ft ² | 168 | 29,113,141 | kWh | | | 51,725 | Litre | 37,516 | Metric Tonne | 6,359,777 | 52 |
| Victoria Family Medical Centre | Facilities used for hospital purposes | 60 Chesley Ave. | 12,100 | ft ² | 168 | 107,079 | kWh | 10,945 | m ³ | | | | | 24,499 | 18 |
| Victoria Hospital | Facilities used for hospital purposes | 800 Commissioners Rd. E. | 2,175,298 | ft ² | 168 | 17,675,915 | kWh | 19,968,641 | m ³ | 16,017 | Litre | | | 38,425,404 | 106 |